
W A L C H E M

IWAKI America Inc.

**CONTACTING CONDUCTIVITY
GENERAL PURPOSE SENSORS
Instruction Manual**

Notice

© 2018 WALCHEM, Iwaki America Inc. (hereinafter "Walchem")
5 Boynton Road, Holliston, MA 01746 USA
(508) 429-1110
All Rights Reserved
Printed in USA

Proprietary Material

The information and descriptions contained herein are the property of WALCHEM. Such information and descriptions may not be copied or reproduced by any means, or disseminated or distributed without the express prior written permission of WALCHEM, 5 Boynton Road, Holliston, MA 01746.

This document is for information purposes only and is subject to change without notice.

Statement of Limited Warranty

WALCHEM warrants equipment of its manufacture, and bearing its identification to be free from defects in workmanship and material for a period of 24 months for electronics and 12 months for mechanical parts and electrodes from date of delivery from the factory or authorized distributor under normal use and service and otherwise when such equipment is used in accordance with instructions furnished by WALCHEM and for the purposes disclosed in writing at the time of purchase, if any. WALCHEM's liability under this warranty shall be limited to replacement or repair, F.O.B. Holliston, MA U.S.A. of any defective equipment or part which, having been returned to WALCHEM, transportation charges prepaid, has been inspected and determined by WALCHEM to be defective. Replaceable elastomeric parts and glass components are expendable and are not covered by any warranty.

THIS WARRANTY IS IN LIEU OF ANY OTHER WARRANTY, EITHER EXPRESS OR IMPLIED, AS TO DESCRIPTION, QUALITY, MERCHANTABILITY, FITNESS FOR ANY PARTICULAR PURPOSE OR USE, OR ANY OTHER MATTER.

180543.E
March 2018

Table of Contents

1.0 Introduction..... 4

2.0 Specifications..... 4

3.0 Installation..... 4

4.0 Maintenance..... 8

1.0 Introduction

The contacting conductivity sensors measure a voltage drop between two electrodes which is inversely proportional to the conductivity of the solution.

2.0 Specifications

2.1 Measurement Performance

Part Number	Cell Constant	Range	Resolution	Accuracy
103903-10	0.01	0-300 $\mu\text{S}/\text{cm}$	0.01 $\mu\text{S}/\text{cm}$	$\pm 1\%$ of reading
103904-10	0.1	0-3,000 $\mu\text{S}/\text{cm}$	0.1 $\mu\text{S}/\text{cm}$	$\pm 1\%$ of reading
103905-10	1.0	0-30,000 $\mu\text{S}/\text{cm}$	1 $\mu\text{S}/\text{cm}$	$\pm 1\%$ of reading
103906-10	10	0-300,000 $\mu\text{S}/\text{cm}$	10 $\mu\text{S}/\text{cm}$	$\pm 1\%$ of reading

Note: Conductivity ranges above apply at 25°C. At higher temperatures, the range is reduced per the range multiplier chart.

Temperature °C	Range Multiplier	Temperature °C	Range Multiplier
0	181.3	80	43.5
10	139.9	90	39.2
15	124.2	100	35.7
20	111.1	110	32.8
25	100.0	120	30.4
30	90.6	130	28.5
35	82.5	140	26.9
40	75.5	150	25.5
50	64.3	160	24.4
60	55.6	170	23.6
70	48.9	180	22.9

2.2 Mechanical

Part Number	103903-10	103904-10	103905-10	103906-10
Length	5.25" (133 mm)	5.25" (133 mm)	5.25" (133 mm)	9.25" (235 mm)
Minimum immersion length	2.25" (57 mm)	0.5" (12.7 mm)	0.5" (12.7 mm)	5.25" (133 mm)
Diameter	0.5" (12.7 mm)			
Pressure (Polypropylene fitting)	0-100 psi (0-6.9 bar)			
Pressure (316SS fitting)	0-200 psi (0-13.8 bar)			
Temperature (Polypropylene fitting)	32-212 °F (0-100 °C)			
Temperature (316SS fitting)	32-248 °F (0-120 °C)			
Fitting Process Connection	½" NPTM			
Electrode Material	316SS			
Insulator Material	PTFE			
O-Ring Material	EPR			
Temperature Element	Pt1000 RTD			
Cable length	10 feet (3 m)			
Maximum cable length	250 feet (76 m)			

3.0 Installation

3.1 Mechanical Installation

General Guidelines

- Mount the sensor as close as possible to the controller.

- Take care to shield the cable properly.
- Maximum cable length is 250 feet.
- Position the sensor such that a fresh, representative sample of the solution is available.
- Position the sensor such that air bubbles will not be trapped within the sensing area.
- Position the sensor where sediment or oil will not accumulate within the sensing area.
- If cable is installed in metal conduit (recommended), either flexible conduit should be used or some other provision made for removal of sensor from the process for maintenance.

Submersion Installations

The submersion sensor requires a standard 1/2" NPTF coupling (user supplied) for connection of the sensor fitting to a standard compatible pipe. The sensor should be immersed away from the walls and floor of the tank by a minimum of 2 inches. The support pipe must be long enough to be above solution level. It should be sealed at the top, with a user supplied cable clamp, to prevent moisture from filling the pipe. See Figure 1. This pipe will usually be suspended from a bracket attached to the lip of the tank.

If the cable run will be exposed to moisture (rain, hosing, etc.), it must be protected with flexible conduit (preferably metal).

In-Line Installations

Thread the fitting into the end port of a 1/2" NPTF tee as shown in Figure 2.

NOTE: *It is important that the flow direction is in the end port and out the side port (as shown in Figure 2) to provide maximum cleaning of the sensor.*

If the sensor will be exposed to moisture (rain, hosing, etc.) the cable end must be protected.




Figure 1 Submersion Installation




Figure 2 In-Line Installation

3.3 Electrical Installation

Route the cable through one of the water tight cable glands on the W100, W600 or W900 series controller, and connect the wires matching the wire label with the terminal block label.

4.0 Maintenance

4.1 Cleaning the sensor

Note: the controller must be recalibrated after cleaning the probe.

- The probe should be cleaned periodically. The frequency required will vary by installation. In a new installation, it is recommended that the probe be cleaned after two weeks of service. To determine how often the probe must be cleaned, follow the procedure below:
- Read and record the conductivity.
- Remove, clean and replace the conductivity probe.
- Read conductivity and compare with the reading in step 1 above.
- If the variance in readings is greater than 5%, increase the frequency of probe cleaning. If there is less than 1% change in the reading, the probe was not dirty and can be cleaned less often.

Cleaning Procedure

An accumulation of dirt or debris on the sensor can affect the accuracy and the thermal time constant. This accumulation should be removed periodically. This can be accomplished by scrubbing with a toothbrush or stiff bottle brush. Detergent or isopropyl alcohol cleaner may help remove oils. A mild acid will remove calcium scale. Harsh abrasives should be avoided. Rinse the sensor thoroughly before returning to service.